

## Laboratory Examination Report

**REPORT TO:**

City of Santa Rosa,  
Municipal Service Center  
69 Stony Circle  
Santa Rosa, CA 95407

METHOD	ANALYTE	RESULT	UNITS	RL	ANALYZED	QUALIFIER
NN11194	Farmers Lane Well 02	Collected: 1/7/14 09:07	Recieved: 1/7/14 13:20	Sampler: WHITEHURST (D)		
EPA 1625C	n-Nitrosodimethylamine	ND	µg/l	0.0020	1/14/2014 07:15	
EPA 504.1	1,2-Dibromo-3-chloropropane	ND	µg/l	0.0099	1/9/2014 09:02	
EPA 504.1	1,2-Dibromoethane (EDB)	ND	µg/l	0.020	1/9/2014 09:02	
EPA 505	Alachlor	ND	µg/l	0.97	1/10/2014 11:31	
EPA 505	Arochlor 1016	ND	µg/l	0.25	1/10/2014 11:31	
EPA 505	Arochlor 1221	ND	µg/l	0.18	1/10/2014 11:31	
EPA 505	Arochlor 1232	ND	µg/l	0.22	1/10/2014 11:31	
EPA 505	Arochlor 1242	ND	µg/l	0.25	1/10/2014 11:31	
EPA 505	Arochlor 1248	ND	µg/l	0.29	1/10/2014 11:31	
EPA 505	Arochlor 1254	ND	µg/l	0.32	1/10/2014 11:31	
EPA 505	Arochlor 1260	ND	µg/l	0.35	1/10/2014 11:31	
EPA 505	Chlordane	ND	µg/l	0.097	1/10/2014 11:31	
EPA 505	Endrin	ND	µg/l	0.097	1/10/2014 11:31	
EPA 505	Heptachlor	ND	µg/l	0.0097	1/10/2014 11:31	
EPA 505	Heptachlor epoxide	ND	µg/l	0.0097	1/10/2014 11:31	
EPA 505	Lindane (gamma-BHC)	ND	µg/l	0.19	1/10/2014 11:31	
EPA 505	Methoxychlor	ND	µg/l	9.7	1/10/2014 11:31	
EPA 505	PCBs as Decachlorobiphenyl (DCB)	ND	µg/l	0.48	1/10/2014 11:31	
EPA 505	Toxaphene	ND	µg/l	0.97	1/10/2014 11:31	
EPA 515.4	2,4,5-T	ND	µg/l	1.0	1/10/2014 07:38	
EPA 515.4	2,4,5-TP (Silvex)	ND	µg/l	1.0	1/10/2014 07:38	
EPA 515.4	2,4-D	ND	µg/l	10	1/10/2014 07:38	
EPA 515.4	2,4-DB	ND	µg/l	2.0	1/10/2014 07:38	
EPA 515.4	3,5-Dichlorobenzoic acid	ND	µg/l	1.0	1/10/2014 07:38	
EPA 515.4	Acifluorfen	ND	µg/l	0.20	1/10/2014 07:38	
EPA 515.4	Bentazon	ND	µg/l	2.0	1/10/2014 07:38	
EPA 515.4	Dacthal acid metabolites	ND	µg/l	2.0	1/10/2014 07:38	
EPA 515.4	Dalapon	ND	µg/l	10	1/10/2014 07:38	
EPA 515.4	Dicamba	ND	µg/l	1.5	1/10/2014 07:38	
EPA 515.4	Dichloroprop	ND	µg/l	1.0	1/10/2014 07:38	

## Laboratory Examination Report

**REPORT TO:**

City of Santa Rosa,  
Municipal Service Center  
69 Stony Circle  
Santa Rosa, CA 95407

METHOD	ANALYTE	RESULT	UNITS	RL	ANALYZED	QUALIFIER
<b>NN11194      Farmers Lane Well 02      Collected: 1/7/14 09:07      Recieved: 1/7/14 13:20      Sampler: WHITEHURST (D)</b>						
EPA 515.4	Dinoseb	ND	µg/l	2.0	1/10/2014 07:38	
EPA 515.4	Pentachlorophenol	ND	µg/l	0.20	1/10/2014 07:38	
EPA 515.4	Picloram	ND	µg/l	1.0	1/10/2014 07:38	
EPA 525.2	2,2,3,3,4,4,6-Heptachlorobiphenyl	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	2,2,3,3,4,5,6,6-Octachlorobiphenyl	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	2,2,3,4,6-Pentachlorobiphenyl	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	2,2,4,4,5,6-Hexachlorobiphenyl	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	2,2,4,4-Tetrachlorobiphenyl	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	2,3-Dichlorobiphenyl	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	2,4,5-Trichlorobiphenyl	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	2-Chlorobiphenyl	ND	µg/l	0.55	1/17/2014 11:47	
EPA 525.2	Acenaphthylene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Alachlor	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Aldrin	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Benz(a)anthracene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Benzo(a)pyrene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Benzo(b)fluoranthene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Benzo(g,h,i)perylene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Benzo(k)fluoranthene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Butachlor	ND	µg/l	0.55	1/17/2014 11:47	
EPA 525.2	Butyl benzyl phthlate	ND	µg/l	0.82	1/17/2014 11:47	
EPA 525.2	Butylate	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Chloroneb	ND	µg/l	0.55	1/17/2014 11:47	
EPA 525.2	Chloroprotham	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Chlorpyrifos	ND	µg/l	0.55	1/17/2014 11:47	
EPA 525.2	Chrysene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Cycloate	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Di(2-ethylhexyl)adipate	ND	µg/l	1.6	1/17/2014 11:47	
EPA 525.2	Di(2-ethylhexyl)phthalate	ND	µg/l	2.2	1/17/2014 11:47	
EPA 525.2	Diethyl phthalate	ND	µg/l	1.6	1/17/2014 11:47	
EPA 525.2	Dimethyl phthalate	ND	µg/l	1.6	1/17/2014 11:47	
EPA 525.2	Di-n-butyl phthlate	ND	µg/l	1.6	1/17/2014 11:47	

## Laboratory Examination Report

**REPORT TO:**

City of Santa Rosa,  
Municipal Service Center  
69 Stony Circle  
Santa Rosa, CA 95407

METHOD	ANALYTE	RESULT	UNITS	RL	ANALYZED	QUALIFIER
<b>REPORT TO:</b> City of Santa Rosa, Municipal Service Center 69 Stony Circle Santa Rosa, CA 95407						
<b>NN11194</b>	<b>Farmers Lane Well 02</b>	<b>Collected: 1/7/14</b>	<b>09:07</b>	<b>Receieved: 1/7/14</b>	<b>13:20</b>	<b>Sampler: WHITEHURST (D)</b>
METHOD	ANALYTE	RESULT	UNITS	RL	ANALYZED	QUALIFIER
EPA 525.2	Diphenamid	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Fluorene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Hexachlorobenzene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Hexachlorocyclopentadiene	ND	µg/l	2.2	1/17/2014 11:47	
EPA 525.2	Indeno(1,2,3-cd)pyrene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Lindane (gamma-BHC)	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Methoxychlor	ND	µg/l	0.55	1/17/2014 11:47	
EPA 525.2	Metolachlor	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Metribuzin	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Molinate	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Napropamide	ND	µg/l	0.55	1/17/2014 11:47	
EPA 525.2	Pebulate	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Permethrins (mixed isomers, total)	ND	µg/l	0.55	1/17/2014 11:47	
EPA 525.2	Phenanthrene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Propachlor	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Propazine	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Pyrene	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Triadimefon	ND	µg/l	1.1	1/17/2014 11:47	
EPA 525.2	Trifluralin	ND	µg/l	0.22	1/17/2014 11:47	
EPA 525.2	Vernolate	ND	µg/l	0.22	1/17/2014 11:47	
EPA 531.1	3-Hydroxycarbofuran	ND	µg/l	3.0	1/10/2014 14:12	
EPA 531.1	Aldicarb	ND	µg/l	3.0	1/10/2014 14:12	
EPA 531.1	Aldicarb Sulfone	ND	µg/l	4.0	1/10/2014 14:12	
EPA 531.1	Aldicarb Sulfoxide	ND	µg/l	3.0	1/10/2014 14:12	
EPA 531.1	Carbaryl	ND	µg/l	5.0	1/10/2014 14:12	
EPA 531.1	Carbofuran	ND	µg/l	5.0	1/10/2014 14:12	
EPA 531.1	Methiocarb	ND	µg/l	2.0	1/10/2014 14:12	
EPA 531.1	Methomyl	ND	µg/l	2.0	1/10/2014 14:12	
EPA 531.1	Oxamyl	ND	µg/l	20	1/10/2014 14:12	
EPA 531.1	Propoxur	ND	µg/l	2.0	1/10/2014 14:12	
EPA 549.2	Diquat	ND	µg/l	4.0	1/10/2014 10:37	

## Laboratory Examination Report

**REPORT TO:**

City of Santa Rosa,  
Municipal Service Center  
69 Stony Circle  
Santa Rosa, CA 95407

METHOD	ANALYTE	RESULT	UNITS	RL	ANALYZED	QUALIFIER
NN11194	Farmers Lane Well 02	Collected: 1/7/14 09:07	Received: 1/7/14 13:20	Sampler: WHITEHURST (D)		
EPA 549.2	Paraquat	ND	µg/l	20	1/10/2014 10:37	
EPA 900.0	Gross Alpha	ND	pCi/L	3.0	1/13/2014 00:00	
EPA 900.0	Gross Beta	DNQ	pCi/L	4.0	1/13/2014 00:00	I,J
Analysis Comment:Alpha Result= 0.563 +/- 1.53 pCi/L; Beta Result= 2.78 +/- 1.78 pCi/L. The MDL and prep time were reported from FGL report. RSM 3/3/14						
EPA 300.0	Chloride	22.5	mg/l	2.5	1/28/2014 20:24	
EPA 300.0	Fluoride	ND	mg/l	0.10	1/31/2014 20:43	
EPA 300.0	Nitrate as NO3	Comment	mg/l	2.0	1/21/2014 15:11	
Analysis Comment:Unable to run sample before hold time expired due to instrument problem. See resample NN11314. KS 1/9/14						
EPA 300.0	Sulfate	1.3	mg/l	0.50	1/31/2014 12:28	
EPA 314.0	Perchlorate	ND	µg/l	4.0	1/13/2014 11:00	
SM 2320B	Alkalinity (Total)	240	mg/l	10	1/9/2014 11:30	
SM 2320B	Alkalinity (Carbonate)	ND	mg/l	10	1/9/2014 11:30	
SM 2320B	Alkalinity (Bicarbonate)	240	mg/l	10	1/9/2014 11:30	
SM 2320B	Alkalinity (Hydroxide)	ND	mg/l	10	1/9/2014 11:30	
SM4500NO2-B	Nitrite as NO2 - Drinking Water	ND	µg/l	400	1/8/2014 13:03	
SM 4500H-B	pH	comment	pH	1.0	1/8/2014 11:26	H
Analysis Comment:Estimated pH = 7.8 jm 1/8/14						
EPA 548.1	Endothall	ND	µg/l	45	1/10/2014 09:51	
EPA 547	Glyphosate	ND	µg/l	25	1/10/2014 14:59	
EPA 200.7	Total Hardness by Calculation - mg/L	155	mg CaCO3/L	1.0	1/23/2014 16:10	
EPA 200.8	Aluminum	ND	µg/l	10.0	1/10/2014 05:10	

## *Laboratory Examination Report*

**REPORT TO:**

City of Santa Rosa,  
 Municipal Service Center  
 69 Stony Circle  
 Santa Rosa, CA 95407

METHOD	ANALYTE	RESULT	UNITS	RL	ANALYZED	QUALIFIER
<b>NN11194      Farmers Lane Well 02      Collected: 1/7/14 09:07      Recieved: 1/7/14 13:20      Sampler: WHITEHURST (D)</b>						
EPA 200.8	Antimony	ND	µg/l	2.0	1/10/2014 05:10	
EPA 200.8	Arsenic	DNQ	µg/l	2.0	1/10/2014 05:10	J
EPA 200.8	Barium	54.9	µg/l	1.0	1/10/2014 05:10	
EPA 200.8	Beryllium	ND	µg/l	0.5	1/10/2014 05:10	
EPA 200.8	Cadmium	ND	µg/l	0.25	1/10/2014 05:10	
EPA 200.8	Chromium	DNQ	µg/l	0.5	1/10/2014 05:10	J
EPA 200.8	Copper	ND	µg/l	0.5	1/10/2014 05:10	
EPA 200.8	Lead	ND	µg/l	0.5	1/10/2014 05:10	
EPA 200.8	Manganese	74.0	µg/l	5.0	1/10/2014 05:10	N
EPA 200.8	Nickel	DNQ	µg/l	1.0	1/10/2014 05:10	J
EPA 200.8	Selenium	ND	µg/l	2.0	1/10/2014 05:10	
EPA 200.8	Silver	ND	µg/l	0.25	1/10/2014 05:10	
EPA 200.8	Thallium	ND	µg/l	1.0	1/10/2014 05:10	
EPA 200.8	Zinc	31.2	µg/l	2.0	1/10/2014 05:10	
EPA 200.7	Calcium	30.3	mg/l	0.020	1/14/2014 07:10	
EPA 200.7	Iron	0.169	mg/l	0.050	1/14/2014 07:10	
EPA 200.7	Magnesium	19.3	mg/l	0.200	1/14/2014 07:10	
EPA 200.7	Potassium	8.22	mg/l	1.0	1/14/2014 07:10	1,5
EPA 200.7	Sodium	55.0	mg/l	10	1/14/2014 07:10	1,5
EPA 570/9-84	Aggressive Index for Drinking Water	12.1	A.I.		1/23/2014 16:15	
SM 2150B	Odor test	ND	T.O.N.	1.0	1/14/2014 09:39	
EPA 903.1	Radium 226	ND	pCi/L	0.470	1/18/2014 10:30	3
Analysis Comment:R 226 result = ND +/- 0.261						
EPA 904.0	Radium 228	ND	pCi/L	0.200	1/13/2014 18:30	3
Analysis Comment:Result=ND +/- 0.569						
SM 2510B	Electrical Conductivity	510	µmhos/cm	5.0	1/9/2014 15:06	
SM 2540C	Total Dissolved Solids	320	mg/l	10	1/8/2014 16:12	

## *Laboratory Examination Report*

**REPORT TO:**

City of Santa Rosa,  
Municipal Service Center  
69 Stony Circle  
Santa Rosa, CA 95407

METHOD	ANALYTE	RESULT	UNITS	RL	ANALYZED	QUALIFIER
SM 2130B	Turbidity	0.40	NTU	0.10	1/7/2014 15:23	
EPA 100.2	Asbestos	ND	MFL	0.2	1/9/2014 00:00	
SM 4500-CN-E	Cyanide	ND	mg/l	0.025	1/9/2014 10:08	
SM 2120B	Color SM2120B CA DW in Water	ND	CU	1.0	1/8/2014 17:28	
EPA 1613	2,3,7,8-TCDD	ND	pg/l	5.0	1/13/2014 15:15	
SM 5540 C	Surfactants	ND	mg/l	0.10	1/8/2014 18:43	
EPA 524.2	1,1,1,2-Tetrachloroethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,1,1-Trichloroethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,1,2,2-Tetrachloroethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,1,2-Trichloroethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,1-Dichloroethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,1-Dichloroethene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,1-Dichloropropene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,2,3-Trichlorobenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,2,3-Trichloropropane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,2,4-Trichlorobenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,2,4-Trimethylbenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,2-Dibromoethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,2-Dichlorobenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,2-Dichloroethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,2-Dichloropropane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,3,5-Trimethylbenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,3-Dichlorobenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,3-Dichloropropane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	1,4-Dichlorobenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	2,2-Dichloropropane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	2-Chlorotoluene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	4-Chlorotoluene	ND	µg/l	0.5	1/14/2014 18:27	

## Laboratory Examination Report

**REPORT TO:**

City of Santa Rosa,  
Municipal Service Center  
69 Stony Circle  
Santa Rosa, CA 95407

NN11194 Farmers Lane Well 02		Collected: 1/7/14 09:07	Received: 1/7/14 13:20	Sampler: WHITEHURST (D)		
METHOD	ANALYTE	RESULT	UNITS	RL	ANALYZED	QUALIFIER
EPA 524.2	4-Isopropyltoluene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Benzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Bromobenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Bromochloromethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Bromodichloromethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Bromoform	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Bromomethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Carbon tetrachloride	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Chlorobenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Chloroethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Chloroform	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Chloromethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	cis-1,2-Dichloroethene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	cis-1,3-dichloropropene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Dibromochloromethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Dibromomethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Dichlorodifluoromethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Ethylbenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Freon-113	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Hexachlorobutadiene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Isopropylbenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	m,p-Xylene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Methylene chloride	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Methyl-tert-butyl ether	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Naphthalene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	n-Butylbenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	n-Propylbenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	o-Xylene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	sec-Butylbenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Styrene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	tert-Butylbenzene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Tetrachloroethene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Toluene	ND	µg/l	0.5	1/14/2014 18:27	

**Laboratory Examination Report**

**REPORT TO:**

City of Santa Rosa,  
 Municipal Service Center  
 69 Stony Circle  
 Santa Rosa, CA 95407

NN11194 Farmers Lane Well 02		Collected: 1/7/14 09:07	Received: 1/7/14 13:20	Sampler: WHITEHURST (D)		
METHOD	ANALYTE	RESULT	UNITS	RL	ANALYZED	QUALIFIER
EPA 524.2	trans-1,2-Dichloroethene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	trans-1,3-dichloropropene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Trichloroethene	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Trichlorofluoromethane	ND	µg/l	0.5	1/14/2014 18:27	
EPA 524.2	Vinyl chloride	ND	µg/l	0.5	1/14/2014 18:27	
EDT Reporting Requested		Comment			3/3/2014 08:34	
Analysis Comment: EDT reporting not required per client.						

Qualifiers

- 1 - Batch LFM/D or MS/D outside acceptance limits. Data is accepted based on passing method required LFB and/or QCS/LCS.
- 3 - RPD outside acceptance limits. Data is accepted based on passing LFB.
- 5 - Reporting Limit(s) have been raised to account for sample dilution due to probable matrix interference.
- H - Analysis hold time exceeded, values are estimated.
- J - Detected, Not Quantified (DNQ)
- N - Reporting Limit raised due to analyte concentration in ICB/CCB that exceeds method criteria.

This data has been reviewed and approved for release.

Report Date : 3/4/2014 3:28:09PM



**Shirlee Johnson**  
 Lab Supervisor  
 sjohnson@srcity.org

Digitally signed by Shirlee  
 Johnson  
 Date: 2014.03.04 15:29:13  
 -08'00'