

This document includes the following:

- **Santa Rosa Water Efficient Landscape Policy**
 - **Preliminary Landscape Statement**
 - **Certificate of Conformance**
 - **Certificate of Completion**
 - **City Council Resolution No. 21142, adopting the Water Efficient Landscape Policy**
-

SANTA ROSA'S WATER EFFICIENT LANDSCAPE POLICY

Introduction: The Water Efficient Landscape Policy was adopted by Santa Rosa's City Council on December 22, 1993 in response to California's Government Code Section 65590 which requires local agencies to adopt water efficient landscape regulations. The Policy as adopted is shown below.

The Policy:

CITY OF SANTA ROSA WATER EFFICIENT LANDSCAPE POLICY

Section I. Purpose

The purpose of this policy is to ensure efficient water use by establishing standards for landscape design appropriate to Santa Rosa's climate, soils, water resources, land use and resource planning.

Section II. Applicability

1. This policy applies to all new projects, public and private, with landscaping that require conditional use permit or design review by the City on or after July 1, 1993, and in the following categories: office, commercial, industrial and institutional landscaping; park and greenbelt landscaping; developer-installed landscaping in multiple-family residential and in common areas of single-family residential.
2. This policy does not apply to landscaping in private areas of single-family and multiple-family residential projects. However, residential projects are encouraged to use this policy as guidelines.
3. This policy does not apply to any landscape which is irrigated by reclaimed water.
4. This policy does not apply to any landscapes irrigated by private well water. However, these projects are encouraged to use this policy as guidelines.
5. This policy does not apply to registered historical sites.

6. This policy does not apply to ecological restoration projects that do not require permanent irrigation systems.
7. Parks, playgrounds, sports fields, golf courses, schools and cemeteries are exempt from the turf area limit of this policy. In these projects, turf will be allowed in all areas where functional need for turf is demonstrated. Every other requirement of this policy is applicable.

Section III. Definitions

For purposes of this Policy, the following definitions apply:

Drought resistant cool-season grass - Cool season grasses which can tolerate drought stress. These grasses usually require high-water-use irrigation scheduling to stay green and vital, but will survive under limited water. Examples: turf-type tall fescues e.g., “Medallion” and “Rebel”.

Functional need (for turf) - Turf planting which serves a functional or practical need rather than purely aesthetic purpose. Examples: athletic fields and pedestrian circulation areas.

High-water-use plantings - Annuals, container plantings, and plants recognized as high-water-use (e.g. Alder, Birch, Willow), or plants documented as having a plant factor greater than 0.6.

Hydrozone - A portion of a landscape having plants with similar water needs. Typically, a hydrozone is served by a valve or set of valves with the same type of irrigation hardware and schedule.

Irrigation circuit - A section of an irrigation system, including the piping and sprinkler heads or emitters, that is operated by a single remote control valve.

Low-water-use plants - Plants which are recognized as drought-resistant or low-water-use when established, or plants documented as having a plant factor less than or equal to 0.6.

Microclimate - A section of a landscaped site with unique climatic conditions that affect the amount of water plants within the area use. Examples of landscape microclimates include courtyards, tree understory areas, median islands.

Non-mechanically compacted soil - Soil which has not undergone engineered compaction procedures.

Organic amendment - Any fully organic material added to the soil to improve soil structure, and other physical properties of the soil. Examples: composted sawdust, redwood soil conditioner, compost, peat moss.

Overspray - Water which is discharged from an overhead irrigation system outside the desired planting area, especially water which wets adjacent hard surfaces, e.g., sidewalks, patios, streets.

Plant factor - A number which represents the portion of reference evapotranspiration used by a particular plant. For example: a shrub with a plant factor of 0.5 uses 50% of reference evapotranspiration; a tree with a plant factor of 1.2 uses 120% of reference evapotranspiration.

Porous mulch - A loose material which is applied to the soil surface to reduce evaporation and retard weed growth. Examples of acceptable mulches include: wood chips, decomposed granite, straw, compost.

Project's landscaped area - The parcel area less building, footprints, driveways, paved walks and patios, parking areas and undeveloped open space or designated natural areas. The project's landscaped area does include all areas under irrigation, water features and hardscape other than those noted above.

Project water saving techniques (to mitigate run-off from slopes) - Landscape design techniques which either allows irrigation to be applied at a rate close to the infiltration rate of the soil or which captures and recycles run-off.

Rain shut-off device - A device which automatically shuts the irrigation system off when a measurable amount of rain occurs.

Reference evapotranspiration - A standard calculation of the quantity of water transpired by a reference crop and evaporated from adjacent soil surfaces as measured by the California Irrigation Management Information System (CIMIS) of weather stations.

Registered historical sites - Sites which are registered as historically significant through either national, state, city or county registries.

Runoff - Water which is not absorbed by the soil to which it is applied and runs off onto other areas. Runoff usually occurs when water is applied at a rate greater than the infiltration rate of the soil, and is especially problematic on slopes and on heavy clay soils.

Water feature - Ornamental or functional body of water or fountain.

Section IV. Plant Selection, Water Features, and Use Limitation

1. Turf, high-water plantings (e.g. annuals, container plants) and water features (e.g., fountains, pools) shall all be considered high-water-uses and shall be limited to not more than 40% of the project's landscaped area if non-drought resistant cool-season grass is used, and to no more than 50% of the landscaped area if drought resistant cool-season grass or warm-season grass is used.

2. Plants selected in all other landscaped areas shall be well-suited to the climate, geology and topographic conditions of the site, and shall be low-water-use once established.
3. No turf or high-water-use plants shall be allowed on slopes exceeding 10%, or 25% where other project water saving techniques can compensate for the increased runoff, and where need for such slopes is demonstrated.
4. No turf shall be allowed in areas eight feet wide or less.
5. Plants having similar water use shall be grouped together in distinct hydrozones and shall be irrigated with separate irrigation circuits.
6. Recirculating water shall be used for all water features.

Section V. Soil Conditioning and Mulching

1. A minimum of one foot depth of non-mechanically compacted soil shall be available for water absorption and root growth in planted areas.
2. In areas with overhead irrigation, organic amendment shall be incorporated into the soil to a minimum depth of 6" at a minimum rate of 5 cubic yards per 1000 square feet, or per specific amendment recommendations from a soils laboratory report.
3. A minimum of a two inch layer of porous mulch shall be applied to all exposed soil surfaces of non-turf areas within the landscaped area. Non-porous material, such as plastic sheeting, shall not be placed under the mulch; porous landscape fabric is permitted.

Section VI. Irrigation

1. All planted landscaped areas shall be irrigated with automatic controllers with repeat start-time potential.
2. When the landscape contains more than one type of plant type (turf, ground cover, annual) or a variety of solar exposures, controllers shall have multiple program potential.
3. Separate irrigation circuits shall be provided for different plant types, irrigation methods, solar exposures, microclimates (e.g. understory, courtyard), slopes and soil types.
4. Pressure regulation shall be installed to effect correct operating pressure for each type of irrigation head or drip method.

5. Point application methods (drip, bubbler) shall be used where overhead irrigation would result in overspray, runoff, or non-uniform application.
6. Irrigation delivery systems shall be designed in such a manner that water does not run off or overspray onto adjacent pavement, sidewalks, structures or other non-landscaped areas.
7. Sprinkler heads shall have precipitation rates matched within 20% of one another on each irrigation circuit.
8. Rain shut-off devices shall be installed on each irrigation controller.
9. Check valves shall be installed where elevation differential may cause low head drainage.

Section VII. Documentation for Compliance

The following documentation is to be presented to the City at each of the four steps of review defined below. This documentation is required for compliance with this policy.

STEP 1: PRELIMINARY DESIGN REVIEW

In a Preliminary Landscape Statement, briefly describe the planting and design actions that are intended to meet the requirements of this policy.

STEP 2: FINAL DESIGN REVIEW

The following shall be submitted with a design review application or with a conditional use permit application when involving design review:

- A. The landscape planting design plan that accurately and clearly identifies and depicts:
 - new and existing trees, shrubs, groundcovers, turf, and any other planting areas;
 - plants by botanical name and common name;
 - plant sizes and quantities;
 - property lines, new and existing building footprints, streets, driveways, sidewalks and other hardscape features;
 - pools, fountains, water features,
- B. A conceptual irrigation design plan or statement which describes irrigation methods and design actions that will be employed to meet the irrigation specifications of this policy.

STEP 3: BUILDING PERMIT/PLAN CHECK

The following shall be submitted with the building permit application:

- A. The planting design as submitted at step 2.
- B. The irrigation plan drawn at the same scale as the planting plan that accurately and clearly identifies and depicts:
 - irrigation system point of connection;

- irrigation system components, e.g. controller, pipe, remote-control valves, sprinklers and other application devices, rain shut-off device, check valves, pressure regulating devices, backflow prevention devices.
- C. Where slopes exceed 10%, a grading plan drawn at the same scale as the planting plan that accurately and clearly identifies finished grades and spot elevations where contours exist within landscaped areas.
- D. The Certificate of Conformance, completed by the design professional, which substantiate compliance with all requirements of this policy.

STEP 4: COMPLETION OF INSTALLATION

Upon completion of installation of the landscape, the landscape design principal or owner shall submit to the City's Building Department a Certificate of Completion stating the project has been installed as designed, or with documentation of suitable substitutions.

Section VIII. Other Provisions

1. The Design Review Board will consider and may allow the substitution of design alternatives and innovation which may equally reduce water consumption for any of these requirements.
2. The Design Review Board will accept documentation methods, water allowance determination, and landscape and irrigation design requirements of the State of California Model Water Efficient Landscape Ordinance instead of sections 2-6 of these requirements where it can be demonstrated that the State procedure will more effectively address the design requirements of the project.

Section IX. Provisions for Appeal

1. The applicant or any affected person may appeal any final decision of staff to the Design Review Board, or a final decision of the Design Review Board to the City Council by filing a notice of appeal within ten working days of the date of action.
2. The hearing of the appeal shall be set for a time not later than thirty days after the date on which the appeal was filed.
3. The secretary of the Board or City Clerk shall give notice of the time and place of hearing an appeal by the Board or City Council, respectively, by mailing a copy of a notice by first class mail, postage prepaid, to the applicant, the appellant, and any other person who has filed a written request for such notice with the secretary or City Clerk. The form of notice of hearing appeal shall be as set forth in the Zoning Code.

CITY OF SANTA ROSA
WATER EFFICIENT LANDSCAPE POLICY

Preliminary Landscape Statement

Project Name _____

Project Location _____

Type of Project (e.g., commercial, residential) _____

The Preliminary Landscape Statement is to be submitted at Preliminary Design Review.

Briefly describe the planting and design actions intended to meet the requirements of the Water Efficient Landscape Policy.

Signature

Date

Project Representative

Phone

Address

CITY OF SANTA ROSA
WATER EFFICIENT LANDSCAPE POLICY

Certificate of Conformance

Project Name _____

Project Location _____

Type of Project (e.g., commercial, residential) _____

The *Certificate of Conformance* is to be submitted with the building permit application, together with complete planting, irrigation and, where necessary, grading plans. Complete documentation per Section VIII of this Policy may be submitted instead of the Certificate of Conformance.

Please check all boxes, unless otherwise noted, and fill in appropriate blanks.

I Plant Selection, Water Features, and Use Limitation

1. Check one:

- Turf, high-water-use plantings (e.g. high-water-use plants, container plants) and water feature (e.g.fountains, pools) cover not more than 40% of the project's landscaped area if non-drought resistant cool-season grass is used, and to no more than 50% of the landscaped area if drought resistant or warm-season grass is used.

Type of grass used _____.

Total high-water-use coverage _____ %.

- This project is exempt from the turf area limit of this policy because it falls into one of the following categories: park, playground, sports field, golf course, school, cemetery. (circle appropriate category)

2. Plants selected in all other landscaped areas are well-suited to the climate, geology and topographic conditions of the site, and shall be low-water-use once established.

3. Check one:

- No turf or high-water-use plants are used on slopes exceeding 10%.
- Turf is used on slopes up to 25% with the following special water saving techniques used to compensate for increased run-off: _____

- 4. No turf is used in areas eight feet wide or less.
- 5. Plants having similar water use are grouped together in distinct hydrozones and are irrigated with separate irrigation circuits.

6. Check if water features are used:

- Recirculating water is used for all water features.

II Soil Conditioning and Mulching

- 1. A minimum of one foot depth of non-mechanically compacted soil is available for water absorption and root growth in planted areas.
- 2. Check one:
 - In areas with overhead irrigation, organic amendment is specified to be incorporated into the soil to a minimum depth of 6" at a minimum rate of 5 cubic yards per 1000 square feet.
 - Amendment recommendations from a soils laboratory report are specified, and this report is attached.
- 3. A minimum of a two inch layer of porous mulch is specified to be applied to all exposed soil surfaces of non-turf areas within the landscaped area. No non-porous material, such as plastic sheeting, will be placed under the mulch.

III Irrigation

- 1. All landscaped areas are irrigated with automatic systems with repeat start-time potential.
- 2. Check if appropriate:
 - This landscape contains more than one type of plant type (turf, ground cover, annual) or a variety of solar exposures, therefore controllers with multiple programs are used.

3. Separate irrigation circuits are provided for different plant types, irrigation methods, solar exposures, microclimates, slopes and soil types.
4. Pressure regulation is provided to effect correct operating pressure for each water delivery hardware type (e.g. spray, rotor, drip, bubbler). The specific pressure regulation techniques employed are:
5. Point application methods (drip, bubbler) are used where overhead irrigation would result in overspray, runoff, or non-uniform application.
6. Irrigation delivery systems are designed in such a manner that water does not run off or overspray onto adjacent pavement, sidewalks, structures or other non-landscaped areas.
7. Sprinkler heads have precipitation rates matched within 20 % of one another on each valve circuit.
8. Rain shut-off devices are specified for each irrigation controller.
9. Check valves specified where elevation differential may cause low head drainage.

Signature

Date

Project Design Professional

Phone

Address

CITY OF SANTA ROSA
WATER EFFICIENT LANDSCAPE POLICY

Certificate of Completion

Project Name _____

Project Location _____

Type of Project (e.g., commercial, residential) _____

The *Certificate of Completion* is to be submitted to the Building Department upon completion of landscape installation.

I, _____, do certify that the landscape installation at this site has been: (check one)

Installed as designed.

Installed as designed with the exception of the following suitable substitutions:

Signature

Date

Design Professional, or Owner

Phone

Address

RESOLUTION NO. 21142

A RESOLUTION OF THE COUNCIL OF THE CITY OF SANTA ROSA ADOPTING THE WATER EFFICIENT LANDSCAPING POLICY DATED DECEMBER 3, 1992

WHEREAS, Section 65590 of the Government Code relating to water conservation requires the local agencies to adopt water efficient landscape regulations; and

WHEREAS, the Santa Rosa General Plan sets forth policies which promote the conservation and efficient use of water to prevent the waste of this valuable resource: and

WHEREAS, the Water Efficient Landscaping Policy is consistent with and would further the goals of the General Plan by providing regulations that promote landscape designs, installation and maintenance that is water efficient and water conserving.

NOW, THEREFORE, BE IT RESOLVED, that the Council of the City of Santa Rosa does hereby adopt the Water Efficient Landscaping Policy dated December 3, 1992.

IN COUNCIL DULY PASSED this 22nd day of December, 1992.

AYES: (5) Mayor Casey; Councilmembers Berto, Knight, Pedgrift and Wright

NOES: (0)

ABSENT: (0)

ABSTAIN: (0)

APPROVED: _____
Mayor

ATTEST: _____
Assistant City Clerk

APPROVED AS TO FORM

City Attorney