

## UTILITY GENERAL NOTES

### REQUIRED NOTES ON ALL PLANS

THE USE OF CONTROLLED DENSITY BACKFILL (CDF) WITHIN ANY PUBLIC SEWER OR WATER TRENCH IS NOT ALLOWED UNLESS SPECIFICALLY APPROVED BY THE DIRECTOR OF UTILITIES.

THERE SHALL BE NO UNMETERED CONNECTIONS TO THE CITY OF SANTA ROSA WATER SYSTEM INCLUDING CONNECTIONS BYPASSING THE METER FOR TESTING ONSITE PLUMBING OR FOR OBTAINING CONSTRUCTION WATER. SUCH CONNECTIONS SHALL BE SEVERED BY THE UTILITY DEPARTMENT AND WILL RESULT IN PENALTIES, INCLUDING PAYMENT OF FINES AND ESTIMATED WATER USAGE FEES.

## UTILITY GENERAL NOTES

### PROJECT SPECIFIC REQUIRED NOTES

CONTRACTOR SHALL CONTACT CITY OF SANTA ROSA PUBLIC WORKS DEPARTMENT FOR FINAL INSPECTION OF ALL SEWER MAINS AND LATERALS, ALL SEWER MAINS AND LATERALS MUST BE CLEANED & MANDRELED PRIOR TO CITY ACCEPTANCE.

THE CONTRACTOR SHALL HIRE AN INDEPENDENT TELEVISION INSPECTION SERVICE TO PERFORM A CLOSED -CIRCUIT TELEVISION INSPECTION OF ALL NEWLY CONSTRICTED SEWERS INCLUDING LATERALS FROM THE MAIN TO THE CLEAN-OUT. THE TELEVISIONING SHALL BE PERFORMED PER SECTION 71-1.08 OF THE CITY OF SANTA ROSA SEWER SYSTEM CONSTRUCTION STANDARD SPECIFICATIONS

ALL SEWER PIPE LENGTHS SHOWN ARE MEASURED HORIZONTALLY TO CENTER OF MANHOLES AND CLEANOUTS.

THE CONTRACTOR SHALL ACTIVATE THE PROJECT'S WATERLINES THROUGH THE INSTALLATION OF A SIX INCH WATER METER PRIOR TO CONSTRUCTION OR STORAGE OF COMBUSTIBLE MATERIALS. THE SIX INCH METER, APPURTENANCES AND SUITABLE PIPING SHALL BE SUPPLIED AND INSTALLED BY THE CONTRACTOR AS SHOWN ON STD. 860. THE CONTRACTOR SHALL BE RESPONSIBLE FOR HAVING THE 6" METER CERTIFIED. THE CITY UTILITY DEPARTMENT WILL PLACE A PLAQUE ON THE METER AFTER CERTIFICATION OF METER HAS BEEN OBTAINED. THE ABOVE INSTALLATION SHALL REMAIN IN PLACE UNTIL THE WATER SYSTEM IS ACCEPTED BY THE CITY. THE COST OF WATER WILL BE BORNE BY THE OWNER/DEVELOPER/SUB-DIVIDER. THE LOCATION OF THE BRIDGE METER AND CHECK VALVES WILL BE DETERMINED BY THE CITY PUBLIC WORKS DEPARTMENT'S CONSTRUCTION SECTION.